

NEW

IEC584-3: 1989, Mod
BS4937. Part 30. 1993

CONDUCTORS

(Operating ranges vary with wire size and application) +/-

EXISTING COLOUR CODES

Extension and compensating Leads

CODES

BRITISH
BS1843:1952

AMERICAN
ANSI/MC 96.1

GERMAN
DIN

E	NICKEL CHROMIUM/CONSTANTAN -200°C to 850°C (Nickel Chromium/Copper-Nickel, Chromel/Constantan, TI/Advance, NiCr/Constantan)					EX
J	IRON*/CONSTANTAN 0 to 850°C (Iron/Copper-Nickel, Fe/Konst, Iron/Advance, Fe/Constantan, IC)					JX
K	NICKEL CHROMIUM/ NICKLE* ALUMINIUM -200°C to 1100°C (NC/NA, Chromel/Alumel C/A, T1/T2, NiCr/Ni, NiAl)					KX
N	NICROSIL/NISIL -200°C to 1300°C					NX
T	COPPER/CONSTANTAN -200°C to 400°C (Copper/Copper-Nickel, Cu/Con, Copper/Advance)					TX
RCA SCA	COPPER/COPPER-NICKEL Compensating for Platinum 10% or 13% Rhodium/Platinum (Codes S and R respectively, over Range 0-50°C) (Copper/Cupronic, Cu/CuNi, Copper/No.11 Alloy)					RCA SCA
KCB	COPPER/CONSTANTAN (LOW NICKLE) (Cu/Constantan) Compensating for "K" over Range 0-80°C (CU/Constantan)					KCB
*Magnetic () Alternative and Trade Names			For thermocouple connectors, body colours are as outer sheath colours above	For thermocouple connectors, body colours are as outer sheath colours above		
For thermocouple connectors, body colours are as outer sheath colours above						

EXTENSION /COMPENSATING CABLES

Extension cables are designated by the suffix X (eg JX¹) and compensating cables by the letter C (eg NC). Different alloys may be used in certain circumstances and these are distinguished by additional letters (eg KCB)

THERMOCOUPLE CONNECTORS

New colour coded connectors are marked IEC and have a grey body with a clearly visible colour coded area (with exceptions of the fascia/panels sockets). This is to prevent any confusion regarding the use of the new and old colour coded connectors